



PIMA COUNTY PROCUREMENT DEPARTMENT
130 W. CONGRESS ST., 3RD FLOOR, TUCSON, AZ 85701-1207
PHONE: (520) 724-8161 FAX: (520) 222-1484

Mary Jo Furphy
Procurement Director

November 22, 2019

AMENDMENT NO. ONE (1)

IFB-PO-2000052; INA ROAD CONSTRUCTION DEBRIS LANDFILL PHASE 1 – CLOSURE (2INARD)

Be advised of the following changes, clarifications and/or additions to the above-referenced Solicitation as stated in the following Amendment.

SOLICITATION DUE DATE:

The Bid Due Date has been changed to **Tuesday, December 10, 2019 at 3:00, Local Tucson Time.**

PRE-BID SIGN-IN SHEET:

Included as Attachment 1 to Amendment 1

PLAN SHEETS:

1. "Digital Vector" PDFs of the Plans will be provided to registered Plan Holders registered via American Reprographics Company (ARC). Use of the "Digital Vector" PDFs is at the bidder's sole risk. Updates to the stamped Plans during advertisement will be provided to registered Plan Holders via Amendment. Bidder is responsible for bid based approved (stamped) plan set.
2. A Cut/Fill Summary plan sheet is included as Attachment 2 to Amendment 1.

CLARIFICATIONS, CHANGES, AND/OR ADDITIONS:

1. There is minimal vegetation within the landfill. There is some vegetation located at the new basin location at the West side of the site, and some at the Southeast basin. This vegetation can be considered construction debris and incorporated within the landfill as a part of this regrading project. There is no need to haul this material offsite. The contractor shall determine the best location to place this debris during the work.
2. The one foot of foundation layer soil to be placed by the Contractor needs to be compacted to 85% per Section B02223 3.05. The detention basin berms need to be compacted to 90% per Section B02222 3.01. Compaction of the bottom of the detention basins is not specified. The detention basin bottoms should not be intentionally compacted.
3. Survey is covered in Section A01050. Both construction staking and as-built surveys will be required. A final grade is not specified; however, Contractor will not be required to place more than the one (1) foot of foundation layer soil for the final elevation of each cell as long as drainage is maintained. Additional material will need County approval prior to placement.
4. Section A01025, Proposal Items 7 and 8 state that payment for the construction of Basins B and C will be lump sum. This is consistent with the Bid Sheet.

5. Pima County is supplying the water via the existing standpipe. If the water were to fail, then there is no provision for water in the contract, and Pima County would be responsible to either restore the water source or pay for development of a new source (use of a potable water meter).
6. Pima County prefers to eliminate or reduce closures that impact the Chuck Huckleberry Loop, and will not allow a full closure during the entire construction project. However, in this project it will need to be closed in order to install the culverts or may require short closures for earthwork immediately adjacent. The successful contractor will need to work with County to ensure safety during construction which will include public notifications regarding caution as well as potential closure(s). Contractor will be asked to minimize this impact and expedite work in the area, ensuring a safe condition for weekends. Bidders will need to assume the need to provide fencing to close off the Loop during construction closures, as well as repair to any damage caused by this project as incidental to the work.
7. Remove Specification A01015 Abbreviations and Definitions, Section 1.07 Qualifications and Training, from the Specifications, pages A01015-19 and A01015-20.

QUESTIONS/ANSWERS:

- Q. 1) Is a Hazwoper necessary for this project?
A. 1) No.
- Q. 2) Does Pima County have a required/critical start date for NTP/Construction – or can the 88 working days be scheduled anytime between January 14 and October 31?
A. 2) County is intending to issue the NTP for a construction start the first week of February 2020.

All other requirements and terms of the Solicitation remain unchanged. Failure to include acknowledgment of all amendments may be cause for rejection.

This Amendment is a total of five (5) pages.

If any questions, please contact me via e-mail at Matthew.Sage@pima.gov.

/s/ Matthew Sage

Matthew Sage, CPPB; Procurement Officer

**ATTACHMENT 1 TO AMENDMENT 1
ATTENDANCE FOR PRE-BID MEETING AND SITE-VISIT**

Day/Date/Time: November 19, 2019, 9:00 a.m.
Location: NRPR, 3500 W. River Road, Tucson, Arizona, 85701



IFB-PO-2000052 INA ROAD CONSTRUCTION DEBRIS LANDFILL PHASE 1 CLOSURE (2INARD)

NAME	COMPANY	PHONE	EMAIL	SITE VISIT
Matt Sage	Pima County Procurement	520-724-8272	Matthew.Sage@pima.gov	mts
Nancy Cole <i>NC</i>	Pima County Public Works	XXX-XXX-XXXX	XXXX.XXXX@XXXXX.XXX	
Upsala Nelson	Pima County DEQ	—	—	
Brendan Mills	MP Environmental	928-240-0236	bmills@mpenviro.com	<i>BM</i>
KEITH JOHNSON	TETRA TECH	602-482-6958	KEITH.JOHNSON@TETRA.TECH.COM	<i>KE</i>
BRIAN ROYMEYER	GRANITE	520-748-8800	brian.roymeyer@gcinc.com	<i>BR</i>
CHAD BRUCE	Rummel Construction	480-222-9922	cbruce@rummelconstruction.com	<i>CB</i>
ERIC DECKER	Rummel Construction	480-222-9922	edecker@rummelconstruction.com	<i>ED</i>
Kody Day	Days Excavating	520-625-1965	Kody.Daysexcavating@gmail.com	<i>DE</i>
Nohe Garcia	KE&G Construction	520-999-1572	ngarcia@kegtvs.com	<i>NG</i>
JIM MORRISON	Hunter Contracting Co.	520-954-8390	JAMESM@HUNTERCONTRACTING.COM	<i>JM</i>
LARRY ASHTON	ASHTON	520-624-5500	DWHITE@ASHTONCO.INC.COM	<i>LA</i>
Bryant Smith	Smithco Ent Inc	602-400-0333	bsmith@smithcoaz.com	<i>BS</i>
Rogelio Flores II	Pima County PMO	520-724-9302	rogelio.flores@pima.gov	<i>RF</i>

ATTENDANCE FOR PRE-BID MEETING AND SITE-VISIT

Day/Date/Time: November 19, 2019, 9:00 a.m.
 Location: NRPR, 3500 W. River Road, Tucson, Arizona, 85701



IFB-PO-2000052 INA ROAD CONSTRUCTION DEBRIS LANDFILL PHASE 1 CLOSURE (2INARD)

NAME	COMPANY	PHONE	EMAIL	SITE VISIT
JOE FALCONE	FALCONE BROS & ASSOC. INC	(520) 700-2386	FALCONEBROS@GMAIL.COM	✓
LAZLY HARVEY	HARVEY TRUCKING	520 888 6255	LARRY@HTI TUCSON.	✓
Bill O'Brien	Next Gen	520-561-6467	billo@ngeneng.com	✓
Dave Eaker	Pima County DEQ	—	—	✓

[Handwritten signatures and initials in the right margin]

Cut/Fill Summary

Name	Cut Factor	Fill Factor	2d Area	Cut	Fill
WEST-NORTH	1.00	1.00	337297.23 Sq. Ft.	131804.07 Cu. Yd.	3458.18 Cu. Yd.
WEST-SOUTH	1.00	1.00	248976.22 Sq. Ft.	115340.83 Cu. Yd.	295.76 Cu. Yd.
Totals			586273.45 Sq. Ft.	247144.90 Cu. Yd.	3753.94 Cu. Yd.

