



CORONA de TUCSON FIRE DEPARTMENT

99 E. Tallahassee Dr., Corona de Tucson, AZ 85641
(520)- 762-5007 Fax: (520) 762-5992
17411 S. Rustling Leaf Tr., Corona de Tucson, AZ 85641
(520) 762-9370 Fax (520) 207-1915



AGENDA MATERIAL
DATE 5/19/14 ITEM NO. RA. 27

February 18, 2020

Dear Pima County DOT

This is to inform you of an Arizona State Fire Code non-compliance issue within Pima County, Arizona.

The area of non-compliance is a development at the SE corner of Wentworth Rd and Andrada Rd.

The non-compliance issue involves two (2) Fire Department turn arounds located on either end of Cold Snap Pl. This street is listed as a "minor local road" Road ID # 213381 and 213380, addresses 2499 thru 2587 E Cold Snap Pl – 85641— the turn-arounds on the west end and the east end are hammerheads. Both turn arounds are currently being used as parking spaces for boats, trailers, 5-wheels, small RVs, and trucks.

The turnarounds are and have been required by the Arizona State Fire Code (2003, 2006, 2012) chapter 5, section 503.2.5.

The obstruction of these Fire Department turn arounds are and have been in violation of the Arizona State Fire Code (2003, 2006, 2012) chapter 5, section 503.4

I would like to request NO PARKING signs be installed at both Fire Department turn arounds located at either end of Cold Snap Pl in accordance with Chapter 5 section 503.3

Thank you for your time and please contact me with any question.

Stay Safe

Charlotte Herdliska
Fire Marshal
Corona de Tucson Fire Department
17411 S. Rustling Leaf Trail
Corona, AZ 85641
O-520-762-9370
F- 520-207-1915
C- 520-603-3144

JUN 02 2014 11:41 PM CCK-ED Cap